



**Informal Interpretation Report
Number 7637**



Date September 24, 2015

Edition 2014

Section 501.5

Question:

Is it the intent of this code to now allow bath exhaust to be installed with a material other than metal.

Answer

Yes

Commentary:

See Table 603.4 for minimum sheet metal thickness for single family dwelling units.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.