



**Informal Interpretation Report
Number 7653**



Date October 09, 2015

Edition 2014

Section 707.5.1

Question:

Is it the intent of 707.5.1 to require a roof deck to have a 2 hour fire rating where the top of a 2 hour fire barrier wall is attached and it is providing lateral support to the wall?

Answer

No

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.