



**Informal Interpretation Report
Number 7687**



Date November 13, 2015

Edition 2014

Section C202

Question:

Is it the intent of Chapter C202 definitions of conditioned space to include wall air conditioning units as one method of creating this conditioned space.

Answer

Yes. Wall units can indeed meet the definition in C202:
SPACE, 1. Conditioned Space, a. Cooled Space.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.