



**Informal Interpretation Report
Number 7724**



Date February 08, 2016

Edition 2014

Section 706.3.2

Question:

Is it the intent of this section, that every commercial building that needs a reroof due to age, must have a engineer evaluate the structural diaphragm of the structure prior to the reroof? Assuming there is no structural damage and the new re-roof is like for like.

Answer

Yes

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.