



**Informal Interpretation Report
Number 7769**



Date May 25, 2016

Edition 2014

Section 606.2

Question:

Is it the intent of the removal of the reference to the Alteration Level 1 Reroofing Section (FBC 2014 Section 708) within section 606.2 (when compared to FBC 2010 Repair Section 506.2), to remove the 25% threshold requirement for full roof replacement if we are performing a repair? For instance, if the work classification per Chp 5 is a Repair, can we repair 40% of the roof without referring to Section 708 and/or FBC Building Chapter 15?

Answer

No. A recent Dec Statement was issued on this question.

Commentary:

Please refer to Declaratory (DEC) statement 2015-135 which may found on the Florida Building Commission website. The specific location is:

http://www.floridabuilding.org/Upload/FBC/CodeID_7288_b11d_DS%202015-135%20-%20Davies%20of%20Bracken%20Engineering.pdf

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.