



**Informal Interpretation Report
Number 7784**



Date September 22, 2026

Edition 2014

Section 414.5.3

Question:

Is it the intent of this Code section to require Enclosed Parking Garages, which have required mechanical ventilation, and CO (carbon monoxide) detection systems, to operate automatically on FPL and Emergency or standby power, such as a generator ?

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.