



**Informal Interpretation Report
Number 7823**



Date September 02, 2016

Edition 2014

Section 3108

Question:

Is it the intent of FBC Section 102.4.1 to include superseding the wind speeds indicated in TIA-222-G despite the requirement to use TIA-22-G for tower analyses.

Answer

No. This section does not refer to any other section.

Commentary:

Exception 5 to 1609.1.1 reinforces this.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.