



**Informal Interpretation Report
Number 7861**



Date November 09, 2016

Edition 2014

Section 1710.5.1

Question:

Is it the intent of this section to require labels that show the series number, wind pressures, etc. even on exterior steel doors?

Answer

Yes, this section applies to all exterior windows and doors, regardless of the material used to construct them.

See 1710.5.1 for specifics on permanent and temporary label requirements.

Commentary:

Some door assemblies are manufactured by different companies and as such there is not a single manufacturer to issue a label. These situations are usually handled via a Florida Approval or an NOA that lays out the requirements.

Organizations such as WDMA and AAMA provide individual pieces and parts such as hinges, handles, operators and so on that are individually listed and may be put together to fit a specific need. In this case, much like a fire rating assembly, a product approval, NOA or other acceptable engineering document needs to be presented for acceptance.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This

interpretation is informal, non-binding and subject to acceptance and approval by the local building official.