



**Informal Interpretation Report
Number 7886**



Date June 12, 2017

Edition 2014

Section 1012.2.1

Question:

Is it the intent of FBC-Existing to require fire sprinklers for a structure when a change of occupancy occurs from Group E to Group A-2 with an occupant load greater than 100.

Answer

Yes

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.