



**Informal Interpretation Report
Number 7892**



Date June 05, 2017

Edition 2014

Section 403.3

Question:

Could the exception to section 403.3 for parking garages with no parking attendants reasonably be applied to small stand alone unoccupied ice vending machines, not accessory to any other occupancy or support facility?

Answer

A free standing ice machine in a parking lot is not an occupancy and is not subject to the minimum plumbing facilities.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.