



**Informal Interpretation Report
Number 7900**



Date June 15, 2017

Edition 2014

Section 2222.4.2

Question:

Is it the intent of 222.4.2 (and 2222.5.1) to apply to metal roofing panels?

Answer

Yes, in the HVWZ area. Note, there are some higher wind requirements in a few areas outside the HVHZ areas. The HVHZ area is restricted to Miami/Dade and Broward counties.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.