



**Informal Interpretation Report
Number 7925**



Date May 02, 2017

Edition 2014

Section 1710.5.1.1

Question:

Is it the intent of the code that all exterior doors, including steel doors be labeled in accordance with 1710.5.1.1.

Answer

As per the code section cited in the request, the door must be labeled by the manufacturer, not the distributor. The listing agency sticker with the windload testing must also be applied at the factory, not after it left the factory. Notify the listing agency about the mis-application of the label and the practice will get corrected.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.