



**Informal Interpretation Report
Number 7932**



Date June 05, 2017

Edition 2014

Section R105.1.1.1

Question:

Is it the intent of this paragraph to allow the use of REScheck for NEW CONSTRUCTION residential buildings of three stories or less?

Answer

Yes

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.