



**Informal Interpretation Report
Number 7949**



Date August 17, 2017

Edition 2014

Section 1514.2.5.3

Question:

Is it the intent of the current code in effect, to relocate where an existing penetration of a plumbing vent stack within the valley area, on an existing home built under 1969 SFBC

Answer

The building codes are not retroactive. As per the existing building code, depending on the level of renovation it may be necessary. If it is a change of use that might also require the upgrade. If it is working fine but there is no changes to the structure then no modification would be needed. More specific details of the situation must be submitted for a more definite answer.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.