



**Informal Interpretation Report
Number 7960**



Date May 11, 2017

Edition 2014

Section 504.6.2

Question:

Is it the intent of Section 504.6.2 to provide a more relaxed regulation for domestic dryer then the general requirement of Section 504.4?

Answer

No, the code prohibits a dryer duct extending into or through ducts or plenums. Section 504.6.2 has more specific information where deemed necessary. For example: the diameter of the duct, direction of the joints, thickness of material, duct support, etc.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.