



**Informal Interpretation Report
Number 7963**



Date September 19, 2017

Edition 2014

Section 2002.4

Question:

Is it the intent of Table 2002.4 to apply to screened walls that are attached to the structure and not wholly or partly self supported.

Answer

This is okay up to the height limits of Table 2002.4A

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.