



**Informal Interpretation Report
Number 7981**



Date September 05, 2017

Edition 2014

Section 101.1.2 , 106.5 " Facility " & 213.2

Question:

Is an open RV & Boat Storage yard considered a "Facility" by definition and would it have to be fully Accessible ? Also , can this type of commercial business operate without providing an accessible toilet room? Sec. 213.2 only requires accessible toilet rooms "Where Provided" & no toilet facilities are planned.

Answer

There does not appear to be structures on the property other than the shed. If the shed is accessible then you are done,

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.