



**Informal Interpretation Report
Number 7982**



Date September 05, 2017

Edition 2014

Section 403.1

Question:

Can a commercial business operate an open RV & Boat storage yard / facility without providing plumbing facilities on site?

Answer

No. While it is open storage, there will obviously be persons present as is evidenced by the boat wash area. It is not uncommon for persons to spend time washing and waxing and doing minor maintenance on RVs or boats at such facilities. It is possible that a single facility for both sexes could be provided depending on the occupant load of the area.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.