



**Informal Interpretation Report
Number 8005**



Date September 27, 2017

Edition 2014

Section 202

Question:

Is it the intent of the code to classify a hotel room or motel room that is provided with kitchenette with a cooking appliance as a "DWELLING UNIT", as opposed to a "SLEEPING UNIT"?

Answer

Yes

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.