



Informal Interpretation Report Number 8129



Date June 08, 2018

Edition 2017

Section P2903.5

Question:

Was the purpose of this change in wording (taking out the quick closing valve requirement) to remove the mandatory requirement of water Hammer arrestors on washer boxes, ice maker boxes and dishwasher connections in residential construction.

Answer

Yes – but some background may be useful. Please see the attached commentary.

Commentary:

The change in wording in P2903.5 actually occurred more than ten years ago during the 2009 I-Code development cycle (the base code for the 2010 FBC.) Prior to that time, requirements for water hammer arrestors were identical in both the IPC (604.9) and the IRC (P2903.5.)

At the code hearings in 2006, identical code changes were proposed for both the IPC and the IRC, striking the mandatory requirement for water hammer arrestors “where quick-closing valves are utilized.” (The proponent’s reasoning was that requiring water hammer protection in all cases was overly-restrictive.) The IRC committee approved the change; the IPC committee did not.

The resulting conflict between the two codes has sowed confusion among designers, installers, and code officials ever since. However, during the 2018 I-Code cycle, the mandatory “quick-closing valve” language was reinstated in the IRC, restoring consistency between the IRC and the IPC. It is possible that Florida will incorporate the new language into the next (7th Edition) Florida Building Code, clarifying that “water hammer arrestors shall be required where quick-closing valves are utilized”, in both the plumbing and the residential codes.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This

interpretation is informal, non-binding and subject to acceptance and approval by the local building official.