



**Informal Interpretation Report
Number 8131**



Date June 08, 2018

Edition 2017

Section 3007.6.4

Question:

If a lobby is provided at the level of exit discharge does the lobby require to meet the minimum size requirement of 150 sq. ft.

Answer

Since it is not a fire service access elevator lobby, no. The lobby would be required to comply with other provisions applying to elevator lobbies.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.