



**Informal Interpretation Report
Number 8139**



Date June 26, 2018

Edition 2017

Section 1017

Question:

Table 1017.2 for S-1 occupancy in a fully sprinkled building allows for 400 feet of exit access distance. Therefore all fully sprinkled S-1 occupancies are allowed 400 feet of exit access distance without using the conditions shown in Section 1017.2.2 Group F-1 and S-1 increase because Table 1017.2 already allows for 400 feet?

Answer

Yes, you are correct. It appears a coordination issue between the 2 tables was required.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.