



**Informal Interpretation Report
Number 8176**



Date October 18, 2018

Edition 2017

Section Table 403.3.1.1 Minimum Ventilation Rates

Question:

Is mechanical exhaust ventilation required for SFR's that have garages ?

Answer

Firstly, the code cited does not apply to SFR. To answer the question, no; unless the blower door test indicates an air infiltration rate of are less than 3 ach thereby triggering a requirement for whole house mechanical ventilation. (FBC-R R303.4)

Commentary:

Refer back to the FBC-Residential, Chapter 15 deals with exhaust systems.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.