



**Informal Interpretation Report
Number 8177**



Date October 18, 2018

Edition 2017

Section 301.15

Question:

Are wall mounted air conditioners allowed to be installed in a window ?

Answer

Yes, Please see FBC M 304.1

Commentary:

In all cases, installation per manufacturer's specifications should be followed.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.