



**Informal Interpretation Report
Number 8417**



Date May 24, 2020

Edition 2017

Section 2709.4 Receptor Drains

Question:

Is it the intent of section 2709.4 to allow a "General Purpose" drain without a flange or weep holes that does not meet approval standards from table 2701.1 to be used in concrete recessed showers that have no liner on the first floor level?

Answer

Yes. See previous BOAF Interpretation #8126. P2709.4 only applies to showers having pans or lining. ASME/ANSI A112.18.2 likewise only references requirements for subdrains for built-up shower pans.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.