



**Informal Interpretation Report
Number 8420**



Date June 02, 2020

Edition 2017

Section 412.4

Question:

Is it the intent of Section 412.4 to require a floor drain in a non-residential aircraft hangar that will be used for storage purposes only?

Answer

Yes. Section 412.4.3 Floor surface. Floors shall be graded AND drained to prevent water or fuel from remaining on the floor. Floor drains shall discharge through an oil separator to the sewer or to an outside vented sump.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.