



**Informal Interpretation Report
Number 8520**



Date April 23, 2021

Edition 2021

Section R403.13.1

Question:

Is it the intent of Section R403.13.1, exception 3 to not allow the connection of a dehumidifier to or from the main return duct of a split system?

Answer

Yes. The intent is to not connect the dehumidified warmer air into the return air of a split system.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.