



**Informal Interpretation Report
Number 8524**



Date April 27, 2021

Edition 2021

Section 1015.4

Question:

Is it the intent of the code to only limit the size of the openings in guards/railings without taking into account the orientation of the pickets?

Answer

Yes

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.