



**Informal Interpretation Report
Number 8534**



Date June 21, 2021

Edition 2021

Section 1010.1.1

Question:

Is it the intent of section 1010.1.1 to allow the use of 6'8" doors in commercial buildings?

Answer

Yes

Commentary:

Section 1010.1.1 States the height of the door opening shall not be less than 80 inches. See Section 1003.3.1 for headroom and the exception (door closures) but it gives the allowance for reduction to 78" minimum.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.