



**Informal Interpretation Report
Number 8582**



Date November 01, 2021

Edition 2021

Section 303

Question:

Is it the intent of the code to classify a membership fitness club with over 50 occupants that offers equipment, yoga studio, personal training, group fitness classes, stationary bike studio, and associated locker rooms but without a basketball court as an A-3 gymnasium?

Answer:

The statement that the occupant load is more than 50 occupants makes this an Assembly Occupancy. However, the requester does not state how the occupant load was determined. Table 1004.5 establishes an occupant load factor of 50 gross for exercise rooms. If the occupant load exceeds 50 using the occupant load factor of 50, it will be classified as an assembly. As a word of caution, the FFPC establishes an occupant load factor of 50 for exercise rooms with equipment and 15 for exercise rooms without equipment.

On 11/01/2021 at 10:06 AM

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.