



**Informal Interpretation Report
Number 8657**



Date June 27, 2022

Edition 2021

Section FBC 2613 Fiber Reinforced Polymer

Question:

Is it the intent of Section 2613 that Fiber Reinforced Polymer shall only be used as allowed in 2613.3, 2613.4, and 2613.5. If Fiber Reinforced Polymer is proposed to be used in any other way would approval by the Building Official in compliance with FBC 104.11 be required?

Answer

Yes, if the single family residence is designed under the FBC Building. Otherwise no. Yes for the second question concerning Building Official approval per 104.11 and would change "required" to "allowed"

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.