



**Informal Interpretation Report
Number 8663**



Date July 01, 2022

Edition 2021

Section 210.8 (A) (7)

Question:

Would a receptacle located under the sink inside the sink base cabinet (supplying power to a garbage disposal) be required to have GFCI protection?

Answer

Not required in the 2017 NEC. See 210.8 for how to measure.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.