



**Informal Interpretation Report
Number 8701**



Date November 14, 2022

Edition 2021

Section R403.13

Question:

Is a dehumidifier allowed to be used for the sole purpose of dehumidification in an attached garage?

Answer

Yes, provided the installation meets the requirements of Section R403.13 FBC, Energy Conservation

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.