



**Informal Interpretation Report
Number 8740**



Date April 11, 2023

Edition 2021

Section 107.3

Question:

If the adequacy of the structural design of a building or part of a building is in question, is it within the purview or potentially even a requirement of the Building Official to request backup (i.e. calculations) from the Design Professional of Record demonstrating the design in question is Code compliant?

Answer

Yes

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.