



**Informal Interpretation Report
Number 8762**



Date May 11, 2023

Edition 2021

Section 230.40, exception 2

Question:

Can a single commercial electrical service consist of separate runs of conductors installed from a utility service transformer to up to 6 service disconnecting means (disconnects not sharing conductors) that are grouped together on a building?

Answer

The answer as posed is yes per NEC 230.2 and 230.40, Exception No. 2. The service conductors would need to be underground and at least 1/0 in size for this exception to apply.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.