



**Informal Interpretation Report
Number 8764**



Date May 06, 2023

Edition 2021

Section 403

Question:

For a Restaurant with 150 fixed seats, is the plumbing fixture count (table 403.1) requirement based on assembly occupants as defined in Sec 403.1.3.1 or is it combined with accessory spaces that have additional occupants by area?

Answer

Per section 403.1 of the Florida Building Code, Plumbing volume, the number of fixtures is based on the TOTAL occupant count determined by the Florida Building Code, Building

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.