



**Informal Interpretation Report
Number 8843**



Date November 11, 2023

Edition 2021

Section 1030

Question:

Are emergency escape and rescue openings required in sleeping rooms in a 2 story R-2 apartment building that has 2 exits and is sprinklered?

Answer

No. Also refer interpretation #s 8713, 8614 and 7948.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.