



**Informal Interpretation Report
Number 8867**



Date March 04, 2025

Edition 2023

Section 454.2.6.1

Question:

Is it the intend of Section 454.2.6.1 and Chapter 34, Adopted Reference Standards including ANSI/PHTA/ICC 7—2020, containing section 4.4.5.1, to require Building Departments to inspect or obtain information at final inspection of pools that verifies actual maximum possible system flow when a TDH calculation is used to demonstrate at plan review compliance with the safe flow of the Suction Outlet Fitting Assembly?

Answer

Yes

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.