



**Informal Interpretation Report
Number 8993**



Date January 10, 2025

Edition 2023

Section 1010.2.11

Question:

Does a well lit, single press button at 38" AAF which reads "press to open" alongside a mag-locked door with no panic bar requirement meet this code?

Answer

Section 1010.2.11 is for the door hardware release of electrically locked egress doors. Your question is more in line with section 1010.2.12, "sensor release of electrically locked egress doors." Section 1010.2.11 is for an electric strike door locking set up, while 1010.2.12 is for the mag lock set up. Your question, if based on a mag lock set would be outlined in section 1010.2.12. If it is simply a push button to operate a door hardware release, then the answer would be no.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.