



Informal Interpretation Report Number 9001



Date February 28, 2025

Edition 2023

Section 810, 1010.1

Question:

Chapter 8 section 810 of the Florida Existing Building Code 8th Edition does not explicitly identify when a change in plumbing fixture type or quantity is required under the alteration level 2 classification.

Therefore, is the intent of the Existing Building Code to defer the requirements for plumbing fixtures to section 1010.1 Florida Existing Building Code 8th Edition such that the change in plumbing fixtures to meet current code requirements is only required when the building or space is subject to a change in occupancy?

Answer

Yes, only when there's a change of occupancy as required in Section 1010.1.

Commentary:

None

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.