



**Informal Interpretation Report
Number 9068**



Date February 28, 2025

Edition 2021

Section 1618.4.6.3

Question:

Does section 1618.4.6.3 only apply to railings located on the exterior of buildings or do interior railings also need to meet this requirement? Also, does the section only apply to the glazing or the entire system (glazing, connections, etc.).?

Answer

1618.4.6.3 applies in all areas of the building. Yes to the glazing and connections as well.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.