



**Informal Interpretation Report
Number 9070**



Date February 28, 2025

Edition 2023

Section 403.1.1

Question:

Is it true that if restrooms are setup as gender neutral, that fixture count can be calculated at 100 percent and the number of fixtures reduced if the occupant count complies with the minimum number?

Answer

Yes, but all urinals shall be within a stall just like the water closets and the requirements for potty parity under F.S. 553.86 must still be met.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.