



**Informal Interpretation Report
Number 9092**



Date May 31, 2025

Edition 2023

Section R320.1.1

Question:

if there are multiple bathrooms on the grade level, provided that one of them has a door which meets the 29 inch clear opening, has the code requirement been satisfied?

Answer

Yes, 1 bathroom door with 29" clear opening would satisfy the code requirement. The Code further stipulates that the accessible bathroom door is to provide maximum possible privacy, If there were choices, the one that would provide maximum privacy should be the one with the accessible door. If only a toilet room is at grade level, it would require the 29" clear opening and satisfy the code requirement.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.