



**Informal Interpretation Report
Number 9093**



Date August 13, 2025

Edition 2023

Section R503.1.2

Question:

Is the minimum standard when replacing duct work in the attic R8?

Answer

Yes, if this is a non conditioned attic.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.