



**Informal Interpretation Report
Number 9101**



Date June 30, 2025

Edition 2023

Section 403 MINIMUM PLUMBING FACILITIES

Question:

Question: is it correct to calculate 1 Water Closet and 1 Lavatory for 100 occupants regardless of sex (Male and Female); meaning 1 of each (1 Water Closet and 1 Lavatory) will suffice for an occupant load of 100 in Storage Occupancy? Unisex?

Answer

Yes

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.