



**Informal Interpretation Report
Number 9124**



Date August 13, 2025

Edition 2023

Section 102.2

Question:

Is the intention of the code to exempt construction office trailers that contain bathroom facilities and are connected temporarily to domestic municipal water supply and sewer from being permitted and inspected for plumbing installations?

Answer

While the temporary building (exception d) or office (exception e) would be exempt Florida Building Code, the temporary connection to any municipal utility would not be exempt.

Commentary:

Please note that 102.2 (e) specifically includes the accessibility provisions.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.