



**Informal Interpretation Report
Number 9141**



Date August 27, 2025

Edition 2021

Section 1030

Question:

Are Emergency Escape and Rescue Opening required in a four story, 13R apartment building with egress stairways at each end of the breezeway, on each story?

Answer

No

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.