



**Informal Interpretation Report
Number 9149**



Date September 16, 2025

Edition 2023

Section 456.4.1.4

Question:

Is the intent of Florida Building Code Section 456.4.1.4 to dictate the minimum number of restrooms required for a food service establishment that seats more than 10 persons?

Answer

The intent is to establish the requirement for 10 persons or less. More than 10 persons would need to meet the requirements of FBC, Plumbing Table 403.1

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.