



**Informal Interpretation Report
Number 9153**



Date September 18, 2025

Edition 2023

Section R328.5

Question:

Is the intent of R328.5 to limit the ESS capacity individually to each of the four indicated locations at a residential dwelling/property?

Answer

The aggregate ratings not to be exceeded apply to each of the 4 locations specified, taken individually. Nothing in the code language of FBC R328 is preventing each of the 4 options from being used simultaneously.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.