



**Informal Interpretation Report
Number 9167**



Date October 16, 2025

Edition 2023

Section C402.5.7

Question:

Is it the intent of C402.5.7, exception number 1, to include 1A* and 2A* (Moist, warm-humid locations)?

Answer

No that is not the intent of the code. C402.5.7 excludes the need of vestibules in climate zones 1A and 2A.

Commentary:

None.

Notice:

The Building Officials Association of Florida, in cooperation with the Florida Building Commission, the Florida Department of Business & Professional Regulation, ICC, and industry and professional experts offer this interpretation of the Florida Building Code in the interest of consistency in their application statewide. This interpretation is informal, non-binding and subject to acceptance and approval by the local building official.